2013

A New Placement and Integration Method of UPQC to Improve the Power Quality in DG Network

Shafiuzzaman K. Khadem
Technological University Dublin

Malabika Basu
Technological University Dublin, mbasu@tudublin.ie

Michael Conlon
Technological University Dublin, michael.conlon@tudublin.ie

Follow this and additional works at: <https://arrow.tudublin.ie/engscheleart>

Part of the [Electrical and Electronics Commons](#)

Recommended Citation

Khadem, S.K.; Basu, M.; Conlon, M.F., "A new placement and integration method of UPQC to improve the power quality in DG network," Power Engineering Conference (UPEC), 2013 48th International Universities' , vol., no., pp.1,6, 2-5 Sept. 2013 doi: 10.1109/UPEC.2013.6715007

This Conference Paper is brought to you for free and open access by the School of Electrical and Electronic Engineering at ARROW@TU Dublin. It has been accepted for inclusion in Conference papers by an authorized administrator of ARROW@TU Dublin. For more information, please contact arrow.admin@tudublin.ie, aisling.coyne@tudublin.ie, gerard.connolly@tudublin.ie.

A new placement and integration method of UPQC to improve the power quality in DG network

Shafiuzzaman K Khadem
Member IEEE

*School of Electrical &
Electronic Engineering, Dublin
Institute of Technology, Ireland*
E-mail: skkhadem@gmail.com

Malabika Basu
Member IEEE

*School of Electrical & Electronic
Engineering, Dublin Institute of
Technology, Ireland*
E-mail: malabika.basu@dit.ie

Michael F Conlon
Member IEEE

*School of Electrical &
Electronic Engineering, Dublin
Institute of Technology, Ireland*
E-mail: michael.conlon@dit.ie

Abstract- A new proposal for the placement and integration of UPQC in DG connected microgrid/micro generation (μ G) system has been presented here. DG converters (with storage), the load and shunt part of the UPQC will be placed at or after the PCC. The series part of the UPQC will be placed before the PCC and in series with the grid. DC link can be connected to the storage system also. Hence, it is termed UPQC μ G. The advantages of the proposed UPQC μ G over the normal UPQC are to compensate voltage interruptions in addition to voltage sags / swells, harmonic and reactive power compensation in the interconnected mode. The DG Converter with storage will supply the active power only and the shunt part of the UPQC will compensate the reactive and harmonic power of the load in the islanding mode. Therefore, the system can work both in interconnected and islanded mode. DG Converter does not require to be disconnected during the voltage disturbance. In all conditions, DG Converter will only provide the active power to the load and grid. Thus it will reduce the control complexity of the DG converter as well as improve the PQ of the network.

Index Terms-- Unified Power Quality Compensator, Microgrid, Power Quality, Distributed Generation, Smart Grid

I. INTRODUCTION

As a part of the integration of the UPQC in a DG connected grid/ μ G system, research to date has been carried out on two techniques; i) (DG-UPQC)_{DC-linked} and ii) (DG-UPQC)_{Separated}. The pros and cons of these configurations are given details in [1]. The main problems for the configurations are i) the control complexity for active power transfer, ii) inability to provide harmonic and reactive power compensation during the islanded mode and iii) difficulty in the capacity enhancement in multi-level or multi-module mode. On the other hand, DG converter shall detect the unintentional islanding and cease to energize the islanded area within two seconds of the formation of an island [2]. One of the reasons is that the controller of the grid-tie DG converter is designed to provide only the active power to the load and grid in the interconnected mode. For a seamless power transfer between the grid-connected operation and islanded mode, that is transfer between the current and voltage control modes of operation along with the robustness against the islanding detection and reconnection delays, research on hybrid control converter is underway [3]. Clearly this will further increase the control complexity of the converter. However, the DG converter needs to be disconnected or to change its control strategy to work in the islanding mode after detecting the

unintentional islanding. To extend the operational flexibility and to improve the power quality in grid connected μ G systems, integration technique of UPQC have been proposed here. The μ G system (with storage), the load and shunt part of the UPQC (APF_{sh}) will be placed at or after the PCC. The series part of the UPQC (APF_{se}) will be placed before the PCC and in series with the grid. DC link can be connected to the storage system also. Hence, it is termed UPQC μ G. The UPQC current sensor, for reactive and harmonic power compensation, will measure only the load current. The main advantages of the proposed UPQC μ G over the conventional UPQC are as follow.

- UPQC μ G will compensate voltage interruptions in addition to voltage sags/swells, harmonic and reactive power compensation in the interconnected mode. Therefore, the DG converter can still be connected to the system during the voltage sag/interrupt condition. Thus it will extend the operational flexibility of the DG converters in the μ G system.
- It will also compensate the reactive and harmonic (QH) power of the load in islanded mode.
- Due to the integration technique, the DG converter will then be more flexible to be islanded.

Both in the current and voltage control modes, the μ G system will provide only the active power to the load. Therefore, it can reduce the control complexity of the converter

II. WORKING PRINCIPLE

The integration technique of the proposed UPQC μ G to a grid connected and DG integrated μ G system is presented in Fig 1(a). The working principle during the interconnected and islanded mode for this configuration is shown in Fig 1(b, c).

A. Interconnected mode

In this mode, as shown in Fig 1(b), the following will happen.

- i. The DG source will deliver only the fundamental active power to the grid, storage and load.
- ii. The APF_{sh} will compensate the reactive and harmonic (QH) power of the non-linear load to keep the THD at the PCC within the IEEE standard limit.
- iii. Voltage sag/swell/interruption can be compensated by the active power from the grid/storage through the APF_{se}. DG

- iv. If the voltage interruption/black out occurs then UPQC will send a signal to the DG converter to be islanded.

In this case, as shown in Fig 1(c), the following will occur.

- i. The APF_{sc} will be disconnected during the grid failure and DG converter will remain connected and maintain the required voltage at PCC.
- ii. The APF_{sh} will still compensate the non-active power of the non-linear load to provide or maintain undistorted current at PCC for other linear loads (if any).
- iii. Therefore, DG converter (with storage) will deliver only the active power and hence does not need to be disconnected from the system.
- iv. The APF_{sc} will be reconnected once the grid power is available.

is directly reconnected (through S4 and S1) to the grid and then sends an activation signal to UPQC_{μG} to prepare for reconnection. After a suitable time, APF_{se} of UPQC_{μG} reconnects through S2 and S3 (by deactivated S4). A detail of the switching mechanism is discussed in the controller design section.

The block diagram of the proposed UPQC_{μG} Controller is shown in Fig 2. It has the same basic functionality as the UPQC controller except for the additional signal generation for islanding detection technique and reconnection capabilities. A communication channel between the proposed UPQC_{μG} and the μG is also required for the detection of islanding and reconnection. This signal generation are based on the sag/swell/interrupt/supply failure conditions. This task is performed in Level 2 (secondary control) of the hierarchical control [4]. Level 1 deals with the primary control of the series and shunt parts of the UPQC to perform their basic functions in the interconnected and the islanded mode. The overall integration technique and control strategy are to improve the power quality during interconnected and islanded modes. This involves detecting islanding and then ensuring that the DG converter remains connected and supplying active power to the load. This reduces the control complexity of the converter as well as the power failure possibility in the islanded mode. As the signal generation for Islanding detection (Sig-IsD) and Synchronization for Reconnection (Sig-SynRec) are new in UPQC therefore, these have been described in details.

In order to ensure the reliable and safe transfer of electrical energy to the grid and load during the interconnected mode, all DG systems should comply with a series of standard requirements given in the international regulations [5]. Considering the future trends towards the smart μ G operation in connection with the distribution grid, the capability of (i) maintaining connection during grid fault condition, (ii) automatically detecting the islanded condition and (iii) reconnecting after the grid fault should be an important feature of the μ G system. In that case, the placement of APF_{se} in the proposed integration method of the system will play an important role by extending the operational flexibility of the DG converter in the μ G system.

In the case of power quality problems, it is reported that more than 95% of voltage sags can be compensated by injecting a voltage of up to 60% of the nominal voltage, with

a maximum duration of 30 cycles [9]. Therefore, based on the islanding detection requirement and sag/swell or other voltage disturbance compensation, a signal is generated for the islanding detection (Sig-IsD) in the proposed UPQC_{μG} to transfer it to the DG converter. As the APF_{se} takes the responsibility for compensating voltage sag/swell/unbalance disturbances (depending on the controller), IsD algorithm in DC converter can be quite flexible and simple.

Fig 2: Block diagram of proposed UPQC_{μG} Controller

Fig 3 shows the algorithm (with an example) that has been used to detect the islanding condition to operate the UPQC_{μG} in the islanded mode. The voltage at PCC is taken here as the reference and it is always in phase with the source and the DG converter, the difference between the $V_{pcc-ref}$ (pu) and V_s (pu) is V_{error} . This error is then compared with the pre-set values (0.1 to 0.9) and a waiting period (user defined n number of cycles) is used to determine the sag/interrupt/islanding condition. In this example, (i) if V_{error} is less than or equal to 0.6, then 60% sag will be compensated for up to 50 cycles; (ii) if V_{error} is in between 0.6 to 0.9, then compensation will be for 30 cycles; (iii) otherwise (if $V_{error} \geq 0.9$) it will be interrupt/black out for islanding after 1 cycle.

Fig 3: Signal generation for Islanding detection (Sig-IsD) method in simulink

This signal generation method is simple and can be adjusted for any time length and V_{error} condition. Thus the flexibility of time and control for compensating the sag can be achieved before islanding. As the seamless voltage transfer from grid connected to isolated mode is one of the critical tasks in transition period, the transfer will be completed at the zero crossing position of the APF_{se}. Therefore, no voltage fluctuation or abrupt conditions will occur.

B. Sig-SynRec

Once the grid system is restored, the μG may be reconnected to the main grid and return to its pre-disturbance condition. A smooth reconnection can be achieved when the difference between the voltage magnitude, phase and frequency of the two buses are minimized or close to zero.

In the case of the UPQC_{μG}, the synchronization for reconnection is done by the DG converter. Once the voltage magnitude, phase angle and frequency differences are within the pre-defined range or are close to zero, then reconnection is made through S4 and S1 as shown in Fig 1. The μG control system then sends a signal $S_{\mu G-R}$ to the UPQC_{μG}. The APF_{se} is then activated and switches S2 and S3 are reconnected to the system by deactivating S4. This switching transition is controlled and performed at a zero crossing condition of V_s . As an example, Fig 4(a) shows a simple synchronization method for reconnection and $S_{\mu G-R}$ is the signal generated by the DG converter. This signal is activated when the phase difference between the utility (V_s) and PCC are within 2 deg in phase and corresponding voltage amplitude difference is within 11.24V. These are observed at a zero crossing of V_s . Fig 4(b) shows the reconnection method of APF_{se} for the UPQC_{μG}. The activated $S_{\mu G-R}$ signal is taken from the μG and passed through a S-R Flip Flop to generate the active signal (Sw4syn) for APF_{se} at the V_s zero crossing condition. This Sw4syn signal is then XOR to the Sw4syn (as shown in Fig 3) to generate the real activation signal for the APF_{se}.

Fig 4: (a) Synchronization method and (b) Sig-SynRec method for UPQC_{μG}

IV. SIMULATION STUDY

A 3-phase, 3-wire active distribution network (230V_{L-N}) with the proposed UPQC_{μG} and μG , as shown in Fig 1, has been developed in the MATLAB environment. The system specifications are as follow; UPQC_{μG} (capability: 100% sag and 100Amax harmonic current compensation) and the μG (Load: 200Amax with harmonic 100Amax; DG: 0.5 to 1.5 times of load fundamentals). Details of the performance with the simulation results are given below. All the simulations have been performed for up to 2 sec. Table 1 shows the timeline for the respective operating conditions.

TABLE 1
TIMELINE OF THE OPERATING CONDITIONS

Operating Condition	Interconnected									Islanded					Interconnected					
	0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9	1.0	1.1	1.2	1.3	1.4	1.5	1.6	1.7	1.8	1.9	2.0
Normal Operation	Phase = 0 deg																			
Sag	50%																			
Sag / Interrupt										90%										
Islanding																				
Synchronization																				
Reconnection																				
DG-input	0.5 Iload				Grid + 0.5 Iload + Storage					Idg + Storage					0.5 Iload				1.5 Iload	

Based on the integration method and signal generation for islanding detection and the reconnection method, Fig 5(a) shows the switch positions (0 for open and 1 for close) during the operation from 0 to 2 sec where both the interconnected and islanded modes are observed. The performance of the proposed UPQC_{μG} for voltage sag compensation is shown in Fig 5(b) and harmonic current compensation is shown in Fig 5(c) based on the Table 1. Performance during the reverse current flow due to the high penetration of DG is also shown by the red circle in Fig 5(c). Details of the performance at different conditions are discussed below. Generally waveforms are shown for phase A only.

A. Interconnected Mode

Depending on the power availability, the DG source can supply power to the load and grid, and therefore by-directional power flow can occur. Hence, the performance of the proposed UPQC should be observed in both cases. For a better understanding, according to the direction of power flow, operation in the interconnected mode can be divided into two parts: (1) forward-flow mode and (2) reverse-flow mode.

a. Forward-flow mode

In this case, the available DG power is less than the required load demand. Therefore, the utility supplies rest of the power to the load which is not met by the DG supply. Fig 6 shows the performance of the APF_{sh} in compensating the reactive and harmonic current generated by the load. As is mentioned in the timeline table, the DG unit supplies 0.5I_{loadf} (half of load fundamental in current control mode) during this time frame. Therefore the remainder of the current is supplied by the utility grid and storage. During a 90% sag condition, the total power for the load demand is still met by the μG system (as shown in Fig 5) and the utility where the storage system provides the power for sag compensation through the DC link.

b. Reverse-flow mode

When the available DG power becomes higher than the required load demand, the extra energy is transferred to the grid and storage and this is termed the reverse-flow mode. At this stage, the grid current becomes out of phase with the voltage at PCC. Fig 7 shows the performance of the system when DG current becomes 1.5I_{loadf} at 1.75 sec and a 30% sag is also applied at 1.85 sec.

Fig 5: (a) Switching positions during the operation; (b) voltage and (c) current waveforms at different conditions and positions in the network.

B. Islanded Mode

According to the Sig-IsD method, the APF_{sc} compensates the sag for up to 0.6 sec (30 cycles) and then the system goes into islanded mode. A utility disconnection is applied at 1.11 sec just after completing the 30 cycle count and then detecting the zero crossing of V_{sag-ref} where S1, S2 and S3 are opened. This is depicted in Fig 8. At disconnection, the μG operates in islanded mode. At this stage, if the available DG power is lower than the load demand, the required power is supplied by the storage. If the DG power is higher than the load, then

the additional power goes to the storage. The APF_{sh} still performs the compensation of non active power. Therefore, DG converter does not need to be disconnected or change the control strategy (supply only the fundamental active power) to supply power to the load.

Fig 6: Performance of APF_{sh} in interconnected and forward flow mode

Fig 8 shows the performance of the proposed UPQC_{μG} during 1.0 to 1.2 sec where the islanding is detected just immediately after 1.1 sec at zero crossing detection. The islanding mode is observed between 1.11 and 1.405 sec. During this period the APF_{sc} is disconnected, as shown in Fig 8(b) where $V_{sag} = 0$, utility current become zero, as shown in Fig 8(c). The APF_{sh} continues to operate, as shown in Fig 8(c), and the load demand is met by the DG with the storage unit.

C. Reconnection

Fig 9(a) shows the different signals for the reconnection process based on the Sig-SynRec method showed in Fig 4. To check the performance of the reconnection process for the worst condition, the utility grid (V_s) is powered on at 1.405 sec where the magnitude is at a maximum, as shown by the red circle in Fig 9(b). Zero crossing detection is also shown. The DG unit sends a reconnection signal, to the UPQC_{μG} unit. Based on the logic given in Fig 11, the actual switch S1 is activated at 1.43 sec and the V_{sag} starts operation, as shown by the red circle in Fig 9(b). S2 and S3 are activated after the synchronization by the DG unit. S4 is disconnected simultaneously at 1.44 sec. This simple algorithm with a combined logic gate ensures the utility connects with the μG smoothly after the utility system is restored.

Fig 9(b) shows that the APF_{sc} unit is immediately reactivated when the grid voltage is available at 1.405 sec but it starts operation when the S2 and S3 switches are closed at 1.43 sec. It is expected that, according to the smooth reclosing condition, no power flow will occur at the point of reclosing. The switching is carried out successfully within the limiting condition as shown in Fig 9(c). The circle at 1.43 sec for I_{dg} and I_s in Fig 9(c) indicates the smooth transition from islanded to interconnected mode. DG converter also changes its control from voltage to current control mode but only

transfers the active fundamental current. The performance of the APF_{sh} is also uninterrupted during the transition period.

D. Power Flow

The power flow diagram is shown in Fig 10 for the complete simulation time where the green line represent the active power (P) and red line (dash) for reactive and harmonic power (QH). This also validates the operation and performance of the APF_{sc} and APF_{sh} part of the proposed UPQC_{μG} along with the islanding detection and reconnection.

Fig 7: Performance; a) APF_{sc}; b) APF_{sh}; interconnected and reverse flow

V. CONCLUSION

This paper describes a new placement and integration technique of the UPQC_{μG} in the grid connected μG condition. The simulation has been performed in MATLAB. The results show that the proposed system can compensate the voltage disturbance at the PCC, the reactive and harmonic current compensation of the load that could inject at the PCC during the interconnected mode. Performance of the UPQC_{μG} is also observed in bi-directional power flow condition. During the islanded mode, the DG converter also only supplies the active power to the load and the shunt APF performs the reactive and harmonic power compensation. Therefore, the grid-tie DG converter does not need to be disconnected or change its control strategy to keep the μG operating during the islanding detection and operation in islanded mode.

Fig 8: Performance -(a) switching, b) APF_{sc}, c) APF_{sh} during islanded mode.

REFERENCES

- [1] S. K. Khadem, M Basu and M F Conlon, UPQC for Power Quality Improvement in DG Integrated Smart Grid Network – A Review, International Journal of Emerging Electric Power Systems, Vol. 13(1), 2012, Art 3
- [2] IEEE 1547, IEEE Standard for Interconnecting Distributed Resources with Electric Power Systems, 2003
- [3] A Kahrobaeian, Y Mohamed, Interactive distributed generation interface for flexible microgrid operation in smart distribution systems, IEEE Trans SE, vol.3(2), pp.295-305, 2012
- [4] J M Guerrero, J Vasquez, J Matas, M Castilla, Hierarchical Control of Droop-Controlled AC and DC Microgrids—A General Approach Toward Standardization, IEEE Trans Industrial Electronics, vol.58, no.1, pp.158-172, Jan. 2011
- [5] R Teodorescu, M Liserre, P Rodríguez, Grid Converters for Photovoltaic and Wind Power Systems, 1st Ed, Wiley IEEE, 2011
- [7] A Kahrobaeian, Y Mohamed, Interactive distributed generation interface for flexible microgrid operation in smart distribution systems, IEEE Trans SE, vol.3(2), pp.295-305, 2012
- [6] H. Kim, T. Yu, S. Choi, Indirect current control algorithm for utility interactive inverters in distributed generation systems, IEEE Trans. PE, vol. 23(3), pp. 1342–1347, May 2008.

Fig 9: Reconnection -(a) switching, (b) APF_{sc}, (c) APF_{sh}

Fig 10: Power flow during the simulation time

- [8] Z Yao, L Xiao, Y Yan, Seamless transfer of single-phase grid interactive inverters between grid connected and stand-alone modes, IEEE Trans. PE, vol.25(6), pp.1597–1603, 2010
- [9] M Brenna, R Faranda, A New Proposal for Power Quality and Custom Power Improvement: OPEN UPQC, IEEE Trans Power Delivery, Vol. 24(4), 2009, pp. 2107-2116